

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-19-10-09-02

Products: SPC floor coverings – Vinyl floorings
Structure: Limestone grain with light embossed raindrop pattern
Thicknesses: 3.2 – 8.0 mm

Client: econfloor Polska Sp.z o.o.
ul. Grel 77
34-471 Ludzmierz
Polska

Order: Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)

Test report: 2718053

Test results:

Properties	Results	Declaration according to EN 14041:2008
Reaction to fire according to EN ISO 9239-1:2010 and EN ISO 11925-2:2011; Abriasion Class Extreme High Traffic - Critical heat flow - Smoke production	Class 42/AC6 0, 026 (m ² K/ W 519 % * min	B _{fl} -s1
Anti-sliding properties according to EN 13893:2003	μ = 0.51	class DS
Formaldehyde emission according to EN 717-1:2004	undetectable	class E1

Dresden, 09/10/2019

R. Gumbel

Head of laboratory



P. J. G.

Engineer in charge